


| | | | |
|---|--|----------------|---|
|  | Canon Elementary School District, #50 Amendment #1 | | 34630 E School Loop Road Black Canyon City, AZ 85324 |
| | Roofing and Weatherization at Canon Elementary School | Page 1 of 5 | |

December 17, 2020

This amendment is released to all interested parties.

1. A non-mandatory pre-bid meeting was held on December 16, 2020. The three page Sign-In Sheet is attached for reference. Items contained within this Amendment are intended to clarify and/or change items within the bid as a result of discussions at meeting and walk-through of the sites.



Canon Sign In.pdf

2. Technical clarifications are attached within Addendum No. 1 from Bob Polcar, Robert Polcar Architects.



Bidders Questions
1.pdf

3. All other terms and conditions remain the same.
4. Please remember to acknowledge this Amendment #1 with your offer.
5. End of Amendment #1.



Canon Elementary School District, #50
Pre-Bid Conference Sign-In Sheet

IIFB: 21-01-21
PROJECT: Roofing and Weatherization at Canon
Elementary School

Page 1
of 3

34630 E School Loop Road
Black Canyon City, AZ 85324

Mandatory: Parking Lot at Canon Elementary School, 34630 E School Loop Road
December 15, 2020 at 10:30 AM (Mountain Standard Time)

| Firm | Representative | Phone | Email |
|-------------------------------------|-----------------------|------------------|-------------------------------------|
| PGPC | Caroline Brackley | 480 797-6873 | Caroline@Pgpc.org |
| RPA | KIRBY SPITLER | 402.317.7209 | kirby@rpaarchitects.com |
| G+G SPECIALTY | Johnny Woodlee | 480-921-4079 | |
| Danson | Devin Fontana | 602-997-0777 | Bfontana@dansonbbg.com |
| G+G SPECIALTY (G.C.) CONTRACTORS | CHARLES GOODBALLET | 480-921- 4079 | ESTIMATING@GGSPECIALTY.COM |
| Boyjin Development | Lance, Boyjain | 602 278-0211 | absolute98@MSA.com |
| Classic Roofing | Brandon Richardson | 602-214- 8549 | Brandon.Richardson@ classicz.com |
| GO TO SERVICES | KEVIN LUMMIS | 480 440 9051 | Kevin.lummis@go4services.net |
| FIVE OLIVER, LLC | Jacob Oliver | 480-720 6323 | Jacob@FiveOliver.com |
| Progressive Roofing | Nick Hadden | 623-210-4694 | nick.hadden@progressiveroofing.com |



Canon Elementary School District, #50
Pre-Bid Conference Sign-In Sheet

IIFB: 21-01-21

PROJECT: Roofing and Weatherization at Canon
Elementary School

Page 2
of 3

34630 E School Loop Road
Black Canyon City, AZ 85324

Mandatory: Parking Lot at Canon Elementary School, 34630 E School Loop Road
December 15, 2020 at 10:30 AM (Mountain Standard Time)

| Firm | Representative | Phone | Email |
|---|-----------------|--------------|------------------------------|
| EDGE CONSTRUCTION | JOE SUMMERS | 602 908 6131 | estimating@edgeconstruct.com |
| LOR Construction 842 E Isabella Ave Mesa Az 85204 Mark Lorenzen PRES 4805071954 mark@lorconstruction.com | | | |
| S&G Construction | CHRIS HAYS | 602 478 1857 | CHAYS@S&GCONSTRUCTION.COM |
| Sun Valley Builders | Kyle Sicard | 602 451 9277 | Kyle@SunValleyBuilders.com |
| Pelicki Co | Drew Phinney | 602 413 9006 | drew@pelicki.com |
| JBS CONTRACTING | STEVE SIMPSON | 602 571 0807 | STEVE@JBS CONTRACTING-AZ.COM |
| CANON ELM #50 | DAVID NORTON | 623-680-7649 | DNORTON@CANONSD50.COM |
| Riddle Painting | Jerry Bowers Jr | 602-790-8054 | jj@riddlepainting.com |
| Chaster Painting | Kevin McDermott | 602-930-6307 | Kevin@chasterpainting.com |
| Sherwin Williams | Nick Fillhauer | 602-370-3913 | nick.d.fillhauer@sherwin.com |

1. QUESTION: School logo on building

"The school logo on the side of the building isn't specifically called out. Would you like us to coat over it and replace it or clear coat over it?"

ANSWER:

Coat over the logo with specified coating. New logo will be applied by District.

2. QUESTION: Detail 101 on Sheet S100

"On S100, detail 101 do you know the existing condition of the block. Is the block fully grouted on the inside like shown on the detail? Would you like us to bid it as if it's fully grouted?"

ANSWER:

We do not know the existing condition of the CMU cell. Assume in your bid that the existing CMU cell is not fully grouted.

3. QUESTION: Thickness of insulation

"The provided drawings and specifications do not list the required depth of iso insulation. Please clarify required thickness."

ANSWER:

The thickness of polyisocyanurate insulation is indicated in the specification. See Section 07 54 19, 1.2.A.5. "Total flat insulation thickness is to be 1-1/2".